

**K.SIVAGURUNATHAN**

**Approved Panel Engineer Class I A**

(By The District Collector, Kanyakumari Dist.)

Office	04652 - 226804
Resi	04652 - 245666
Mobile	94431 68080
Mail ID	ksgn51@gmail.com

**GANESH ASSOCIATES** 1, HINDU COLLEGE ROAD, CHETTIKULAM JUNCTION, KOTTAR, NAGERCOIL - 629 002.

**KS : SSC No : 9011 / 20 / RE**

**15 05 20**

**STATEMENT ACCOMPANYING FORM A**

1. Door No. of the building	13 / 43 - 5	Main Block
2. Location of the building	<small>R Sy Nos. 303/ 8 A, 8 B, 9, 10 A, 10 B, 11, 14 B, 304/ 2 B, 3 B, 4 B, 5, 7 A, 9 A, 10, 305/ 1 B, 2 B, 3, 5 A, 5 B, 6, 7, 9</small> <b>STELLA MARY'S C B S E SCHOOL</b> Vellamodi Jn Ganapathipuram KK Dt - 629 502	
3. Year of construction	2017	
4. Approx. constrn. cost as per current rates	Rs. 50 00 000.00	
5. Purpose for which building is being used/ proposed to be used	School building	
6. Purpose for which building has hitherto been used	School building	
7. Details of construction of the building		
i. Foundation	RCC isolated column footing	
ii. Basement	RCC isolated column footing	
iii. Super Structure	RCC frame & BW in CM	
iv. Floor	PCC & ceramic / cement floor finish	
v. Roof	RCC slab & beams	
8. Period for which licence is required	<b>01 07 20 to 31 05 23 ( 3 years )</b>	
9. Number of persons to be accommodated	<b>3000</b>	Nos.



**K. SIVAGURUNATHAN**  
Approved Panel Engineer

Date: 15 05 20

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh licence, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh licence, if the purpose for which the licence was granted for the use of the building originally is changed or altered subsequently.

Date: SIGNATURE OF THE BUILDING OWNER

# K.SIVAGURUNATHAN

Approved Panel Engineer **Class I A**

(By The District Collector, Kanyakumari Dist.)

Office	04652 - 226804
Resi	04652 - 245666
Mobile	94431 68080
Mail ID	ksgn51@gmail.com

**GANESH ASSOCIATES** 1, HINDU COLLEGE ROAD, CHETTIKULAM JUNCTION, KOTTAR, NAGERCOIL - 629 002.

**KS : SSC No : 9011 / 20 / RE**

**15 05 20**

## FORM - B & C

Form of CERTIFICATE OF STRUCTURAL STABILITY under sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features :

### 1. FOUNDATION :

1. Depth below ground level = 2.0 m average
2. Nature of soil met with at foundation level = Hard Earth
3. Pressure at Foundation = 18.8 t/sqm
4. Probable S B Capacity of the strata met with at foundation = 30.0 t/sqm

### 2. SUPERSTRUCTURE :

1. Maximum stress in the most critical section of masonry and concrete = 20.4 t/sqm
2. Nature of masonry and concrete and its safe permissible stresses = 40.0 t/sqm

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 ( Latest version ) and other relevant I S CODE OF PRACTICE and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A licence may be granted for the period from

**01 07 20 to 31 05 23 ( 3 years )**



**K. SIVAGURUNATHAN**

Approved Panel Engineer

Date : 15 05 20

**K.SIVAGURUNATHAN****Approved Panel Engineer Class I A**

(By The District Collector, Kanyakumari Dist.)

Office : 04652 - 226804

Resi : 04652 - 245666

Mobile : 94431 68080

Mail ID : ksgn51@gmail.com

**GANESH ASSOCIATES 1**, HINDU COLLEGE ROAD, CHETTIKULAM JUNCTION, KOTTAR, NAGERCOIL - 629 002.**KS : SSC No : 9011 / 20 / RE****15 05 20**

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building	Age of bldg	No.of storeys	Short Description	Certified purpose	Certified period	No.of persons to be accommodated
13/43-5	3	<b>GF + 2</b>	RCC framed	<b>School building</b>	Three	<b>3000</b>
<b>STELLA MARY'S CBSE SCHOOL</b>	years	only	structure		Years	Nos.
Vellamodi Jn Ganapathipuram KK Dt - 629 502			RCC slab		<b>MAIN BLOCK</b>	

**DECLARATION**

I, **K.SIVAGURUNATHAN** do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.



Date: 15 05 20

**K. SIVAGURUNATHAN**

Approved Panel Engineer

From

District Collector,  
Kanniyakumari District,  
at Nagercoil.

To

Thiru.K.Sivagurunathan,  
(Ganesh Associates)  
1-Hindu College Road,  
Chettikulam Junction,  
Kottar, Nagercoil.

**E1/28729/2016 dated: 13.06.2017**

Sir,

Sub : Up gradation of the name of private practicing Engineer from Class I to Class IA in Kanniyakumari District - informed - regarding.

Ref : 1. Your Application dated: 28.07.2016.  
2. Engineer-in-Chief, WRO & Chief Engineer (General) PWD, Chepauk, Chennai-5, letter No. AEE/T1/AE/26424/2017, dated: 27.04.2017.

-----

It is hereby informed that your name has been upgraded in the panel of private practicing Engineer from Class I to Class IA Category (Buildings) the cost of which exceeds Rs.50 lakhs in Kanniyakumari District as per Engineer-in-Chief (Buildings) Chief Engineer (Buildings) Chennai Region, Chief engineer (General) PWD, Chennai in the letter read in the reference 2<sup>nd</sup> cited.

Sd/-S.Natarajan,  
For Collector,  
Additional Personal Assistant  
(Land) to Collector,  
Nagercoil.

/True Copy/by Order/

  
Head Assistant(E)

2021.02.27 12:32